

**ADDENDUM NO. 1  
Contract 8-2018  
September 11, 2018**

---

**CONTRACT AND SPECIFICATIONS  
SUGAR MAPLE RIDGE DEVELOPMENT PHASE I  
WATER AND SANITARY SEWER PROJECT**

**CONTRACT 8-2018  
MORGANTOWN UTILITY BOARD  
MORGANTOWN, WV**

This Addendum to the Contract and Specifications is issued to modify, explain, or correct the original Contract and Specifications and is hereby made part of the Contract Documents. Insert the date and number of this Addendum in the blank space provided in Bid Envelope 1, Page B-11, and Bid Envelope No. 2, Page B-17.

\*\*\*\*\*

SPECIFICATIONS

Section 0006 Bid

Replace existing Bid section, pages B-19 to B-20 with the attached Bid section, pages B-19 to B-20 for the following changes:

- A. Bid Item #13 has been corrected to show 6" DR-18 C900 PVC Water Line.


\*\*\*\*\*

**BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACES PROVIDED IN THE BID FORM.**

\*\*\*\*\*

Dated at Morgantown, WV  
September 11, 2018

Morgantown Utility Board  
P.O. Box 852  
Morgantown, WV 26507-0852

By:  \_\_\_\_\_

Cory T. Jones



4. The following abbreviations may be used in this Bid:

CIP -- Complete in Place	LBS -- Pounds
LF -- Linear Foot	CY -- Cubic Yard
LS -- Lump Sum	DI -- Ductile Iron
LT -- Left	DIA -- Diameter
EA -- Each	MH -- Manhole Pipe
EXCL -- Excluding	RCP -- Reinforced Concrete
FT -- Feet	RT -- Right
GAL -- Gallon	SF -- Square Foot
STA -- Station	HRS -- Hours
SY -- Square Yard	IN -- Inch
T -- Ton	INCL -- Including
VLF -- Vertical Linear Foot	MJT -- Mechanical Joint

5. Bidder will complete the work for the following price(s):

**Sugar Maple Ridge Development Phase I  
Water and Sanitary Sewer Project**

Contract 8-2018

**BID SCHEDULE \***

<b>ITEM NO.</b>	<b>DESCRIPTION</b>	<b>QUANTITY*</b>	<b>UNIT</b>	<b>UNIT PRICE</b>	<b>TOTAL PRICE</b>
<b>Item</b>	<b>Description</b>	<b>Quantity *</b>	<b>Unit</b>	<b>Unit Price</b>	<b>Total Price</b>
1	Audio/Video Taping	1	LS		
2	10" SDR-35 PVC - Gravity Sewer Main	1050	LF		
3	10" Ductile Iron Pipe - Gravity Sewer Main	447	LF		
4	8" SDR-35 PVC - Gravity Sewer Main	2045	LF		
5	8" SDR-26 HDPE – Variable Grade Sewer Main	610	LF		
6	16" Steel Casing, Bore and Jack (Includes Carrier Pipe Installed within Casing)	20	LF		
7	16" Steel Casing, Open-cut (Includes Carrier Pipe Installed within Casing)	30	LF		
8	Manhole – Standard	31	EA		
9	Manhole – Drop	2	EA		
10	Sanitary Sewer Service w/ Cleanout	5	EA		
11	Double Sanitary Sewer Service w/Cleanout	15	EA		
12	Concrete Anchors	20	EA		
13	6" DR-18 C900 PVC Water Line	1130	LF		
14	Concrete – Thrust Block	14	CY		
15	Seeding	4790	LF		
16	Street Surface Restoration – Stone	10	SY		
17	Street Surface Restoration – Rt. 48/8 – Stone – Full Width Overlay (3" of 1-1/2" Crusher Run Stone)	1900	SY		
18	Stone Backfill – Unsuitable Material	825	CY		
19	Mobilization***	1	LS		